



MICRO ENGINEERING & TESTING LABORATORY

IAA ISO 9001:2015, ISO 14001:2015 and ISO/IEC 17025:2005 Certified Laboratory

Office:
1-4 First Floor, Mahaveer House,
Ambala, Distt. 1510023
T: 01762-246482 | M: 9815871143-108

Laboratory:
Plot No. 43, FEROZ, Ind. Estate,
P.O. Durgam, Haridwar 1310019
M: 9815871143-108

Email: info@micro.in
Website: www.micro.in

TEST REPORT

Description of Sample: Water

Report No.: METL/20-21-177/0012/51

Date of Report: 27/06/2020

Date of Testing: 25-27/06/2020

Date of Receipt: 25/06/2020

Issued to:

Swarn Prastha Public School
Sonapat, HARYANA

Requirement as per IS: 10500-2012 (Drinking Water)

S. No.	Characteristics	Test Value	Acceptable Limit	Permissible Limit in absence of Alternate Source	Method of Test
1	Colour, Hazen unit, Max.	<5	5	15	IS-3025(P-4)-1983; R-2012
2	Odour	Agreeable	Agreeable	Agreeable	IS-3025(P-5)-1983; R-2012
3	Turbidity, NTU, Max.	<4	1	5	IS-3025(P-10)-1984; R-2012
4	pH Value	6.54	6.5 - 8.5	No Relaxation	IS-3025(P-11)-1983; R-2012
5	Total Hardness, (as CaCO ₃), mg/l Max.	Nd	200	600	IS-3025(P-21)-2009
6	Iron (as Fe), mg/l Max.	0.08	1.0	No Relaxation	IS-3025(P-53)-2003; R-2014
7	Chloride (as Cl ⁻), mg/l Max.	29	250	1000	IS-3025(P-32)-1988; R-2014
8	*Residual Free Chlorine, mg/l Min.	Nd	0.2	1.0	IS-3025(P-26)-1986; R-2014
9	Fluoride (as F ⁻), mg/l Max.	0.13	1.0	1.5	APHA 23 ⁸⁹ Edn. 2017
10	Total Dissolved Solids mg/l Max.	82	500	2000	IS-3025(P-16)-1984; R-2012

Remark: With respect to the above test, water sample conforms IS: 10500-2012.

Note: * To be applicable only when water is chlorinated.

Analyst



Authorized Signatory

Terms & Conditions

1. The result shall be valid only for the tested sample, and applicable parameters and equipment of product & further internal use required.
2. Result validity of test Lab. is limited to the issued test report.
3. Sample will be destroyed after 30 days from the date of issue of test report.
4. This report is not to be reproduced wholly or in part, and cannot be used as an evidence in the court of law and it should be used as a reference only without our special permission in writing.



Principal
Swarnprastha Public School
Sonapat

Manager
Swarnprastha Public School

HYGENIC AND SANITARY CERTIFICATE


No-Dy. CS(H) 20/409

Date: 26/6/2020.

It is certified that Swarnprastha
Public School Sec-19 Near
Omaxe City N.H.1. Sonapat.
was inspected by Dy. Civil Surgeon & Health Inspector.
safe drinking water, hygienic & sanitary/conditions were found satisfactory.

Previous Number 2018/872 Dt: 28/1/18.

The above valid for one year JUNE 2021



GLISH LETTER DELL CMO 2, 2019

Wrover
Principal
Swarnprastha Public School
Sonapat

Amal
Manager
Swarnprastha Public School